

FIRE SAFETY CERTIFICATE

No. 156 / 2025

Date: 20.08.2025


Certified that the **GLAZEBROOK PUBLIC SCHOOL** at survey NO: 7 / 1 & 3, Ward-C, Block-4, Nagaramalai Adivaram, Reddiyur, Salem District, salem-636004 comprised of Ground Floor, First Floor and Second Floor Owned by **GLAZEBROOK PUBLIC SCHOOL** have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officers concerned of Fire Service on 20.08.2025 in the presence of **Mrs. D. NIRMALA**. The Correspondent and that the building is fit for occupancy up to classes XII. With effect from **20.08.2025** for a period of **Three years** in accordance with rule and subject to compliance of specific conditions as appended:-

1. This certificate is valid for Three Years from the date of issue.
2. Fire protection devices shall be placed in (Generator room, Class room, Laboratory and Computer room) the wall or easy to handle as per provisions of National Building Code 2015 and Indian Standards.
3. Water Tanks should always be kept in full.
4. Mock drill should be conducted periodically.
5. Emergency exit signs should be kept in red colour that even glows in the dark.
6. First Aid Kit should be kept and used properly.
7. Do not accumulate waste materials in the School premises.
8. Cooking room should be separate from the School building and LPG gas cylinders should be used safely without leakage.

Issued on 20.08.2025 at Salem by **Mr. P. Sivakumar**, Assistant District Officer,
Salem Fire and Rescue Station.

To.

The Correspondent,
GLAZEBROOKE PUBLIC SCHOOL,
survey NO: 7 / 1 & 3, Ward-C, Block-4,
Nagaramalai Adivaram, Reddiyur,
Salem District,
Salem-636 004



[Signature]
Assistant District Officer
Fire and Rescue Services
Salem - 636 001
Salem District

[Signature]
PRINCIPAL
Glazebrooke Public School.
Nagaramalai Adivaram,
Reddiyur, SALEM - 4